



Northbrook, Illinois • (847) 272-8800
 Melville, New York • (631) 271-6200
 Santa Clara, California • (408) 985-2400
 Research Triangle Park,
 North Carolina • (919) 549-1400
 Camas, Washington • (360) 817-5500

FIKE PROTECTION SYSTEMS, DIV OF
 FIKE CORP
 MR S TITUS
 704 S 10TH ST
 PO BOX 610
 BLUE SPRINGS MO 64013

Your most recent listing is shown below. Please review this information and report any inaccuracies to the UL Engineering staff member who handled your project.

For information on placing an order for UL Listing Cards in a 3 x 5 inch format, please refer to the enclosed ordering information.

GAMT June 23, 2000
 Carbon Dioxide System Units, Total Flooding

FIKE PROTECTION SYSTEMS, DIV OF FIKE CORP
 704 S 10TH ST PO BOX 610, BLUE SPRINGS MO 64013

EX4447

Item	Model or Part No.	Nom Pipe Size In.	Orifice Code Range
"S" Nozzle	C80-010	1/2	1.0 thru 11.5
Vent Nozzle	C80-020	1/2	1.0 thru 13.5
Baffle Nozzle	C80-030	1/2	1.0 thru 13.5
360 deg Radial Nozzle	C80-041	1/2	3.5 thru 13.0
180 deg Radial Nozzle	C80-042	1/2	3.5 thru 13.0
360 deg Radial Nozzle	C80-043	3/4	10.0 thru 19.0
180 deg Radial Nozzle	C80-044	3/4	10.0 thru 17.0
360 deg Radial Nozzle	C80-045	1	15.0 thru 25.0
180 deg Radial Nozzle	C80-046	1	15.0 thru 25.0

LOOK FOR LISTING MARK ON PRODUCT