

消防處  
牌照及審批總區  
香港九龍尖沙咀東部康莊道1號5樓  
消防總部大廈



**FIRE SERVICES DEPARTMENT  
LICENSING AND CERTIFICATION  
COMMAND**

FIRE SERVICES HEADQUARTERS BUILDING,  
No. 1 Hong Chong Road, 5/F.,  
Tsim Sha Tsui East, Kowloon,  
Hong Kong

本處檔號 Our Ref.: (43) in FP 206/0877 VI  
來函檔號 Your Ref.:  
電訊掛號 Telex: 39607 HKFSD HX  
圖文傳真 Fax: (852) 2367 3631  
電子郵件 E-mail: lcpolic2@hkfsd.gov.hk  
電話 Tel. No.: 2733 7596

3 September, 2002

Fike Protection Systems  
Division of Fike Corporation  
704 south 10<sup>th</sup> Street, P.O. Box 610  
Blue Springs  
Missouri 64013  
USA

Dear Sirs,

**Application for Approval of Fire Detection/Control Systems**

I refer to my interim reply of 19.7.2002 on the captioned subject.

The following fire control unit, which was certified by the Underwriters Laboratories Inc. (UL), has already been accepted by this Department for use in Hong Kong :-


<b>Manufacturer</b>	:	Fike Protection Systems, Div. of Fike Corp.
<b>Type</b>	:	Control Units, System
<b>Model</b>	:	Cheetah
<b>Testing Standard</b>	:	UL 864
<b>Test Report</b>	:	File S2203 Project 96NK37349 dated 13.6.1997 issued by Underwriters Laboratories Inc. (UL)

Please note that the acceptance of the above is subject to :-

- i) the installation conforming to FSD Circular Letter No. 1/2002 Rules for Fire Detection and Alarm Systems for Buildings ;

- ii) all conditions as stipulated in the above-mentioned test report being complied with; and
- iii) all components used in the installation being compatible.

Yours faithfully,



(LI Kin-yat)  
for Director of Fire Services

LKY/cwy