

消防處
牌照及審批總區
香港九龍尖沙咀東部康莊道1號5樓
消防總部大廈



**FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION
COMMAND**

FIRE SERVICES HEADQUARTERS BUILDING,
No. 1 Hong Chong Road, 5/F.,
Tsim Sha Tsui East, Kowloon,
Hong Kong

本處檔號 Our Ref.: (46) in FP 206/0877 VI

來函檔號 Your Ref.:

電訊掛號 Telex: 39607 HKFSD HX

圖文傳真 Fax: (852) 2367 3631

電子郵件 E-mail lcpolice2@hkfsd.gov.hk

電話 Tel. No.: 2733 7596

18 September 2002

Fike Protection Systems
Division of Fike Corporation
704 South 10th Street
P.O. Box 610
Blue springs, Missouri 64013
USA

Dear Sirs,

**Application for Approval of Carbon Dioxide System,
Carbon Dioxide "Marine" System & HFC-227ea "Marine" System**

I refer to my interim reply of 29.7.2002 on the captioned subject.

Your submitted documents have been studied. Please be advised that the control on the use of Carbon Dioxide & Clean Agent Fire Extinguishing Systems on vessels is outside the purview of this Department. As such, product approval from this Department is not required. However, you may wish to consult Director of Marine for obtaining further information. The address and contact numbers of Marine Department are as follows :-


Local Vessels Safety Section
Marine Department
(Attn. : Senior Surveyor of Ships)
Harbour Building
38 Pier Road, Hong Kong
Tel. No. : (852) 2852 4430
Fax. No. : (852) 2542 4679

or Cargo Ships Safety Section
Marine Department
(Attn. : Senior Surveyor of Ships)
Harbour Building
38 Pier Road, Hong Kong
Tel. No. : (852) 2852 4510
Fax. No. : (852) 2542 0556

Since Carbon Dioxide Fire Extinguishing System consists of essential components such as nozzles, pipe work, fixing, control valves, actuators, pressure vessels, the extinguishing system shall be evaluated and accepted by this Department on a system basis in accordance with an applicable national/international standard. In this regard, you are advised to submit a full test report on the Carbon Dioxide Fire Extinguishing System for our assessment.

Should you have any queries on this matter, please feel free to contact Mr. CHAN Wai-yin at 2733 7827.

Yours faithfully,

A handwritten signature in black ink, appearing to read 'Robert LAU', written in a cursive style.

(Robert LAU)
for Director of Fire Services

RL/cwy