

RECEIVED

18 DEC 2007

YKK



消防處
牌照及審批總區
香港九龍尖沙咀東部康莊道1號5樓
消防總部大廈

FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION COMMAND
FIRE SERVICES HEADQUARTERS BUILDING,
No.1 Hong Chong Road, 5/F,
Tsim Sha Tsui East, Kowloon,
Hong Kong.

本處檔號 OUR REF. : (21) in FP 206/0877 VIII
來函檔號 YOUR REF. : FS/E&M/43/016
電子郵件 E-mail : <lcpolic2@hkfsd.gov.hk>
圖文傳真 FAX : 2367 3631
電話 TEL NO. : 2733 7605

Please try whether it belongs to BEP-ME
If not, please return to GAD immediately.

14 December 2007

The Jardine Engineering Corporation, Limited
13/F, Somerset House, TaiKoo Place
979 King's Road
Hong Kong

Dear Sirs,

Application of Acceptance of Fixed Gaseous Fire Extinguishing System

I refer to my interim reply of 3 October 2007 on the captioned subject.

Please be informed that the following fire extinguishing system, which is certified by FM Approvals (FM), has already been accepted by this Department. As such, application to this Department for acceptance again is not required:-

- Manufacturer** : Fike Corporation
- Type** : Inert Gas Fire Extinguishing System
- Model** : ProInert IG-55
- Testing standard** : UL 2127
- Supporting Documents** : FM Approvals Report Project ID. 3025843 dated 5 April 2007; and

Design, Installation and Maintenance Manual for ProInertTM Fire Extinguishing System P/N 06-371 dated April 2007.

...../P.2

Please note that the above acceptance is valid subject to:-

- i. all conditions as stipulated in the above-mentioned test report being complied with;
- ii. the cylinders used to contain any gas for the fire extinguishing system being approved by this Department in accordance with Regulation 64 of the Dangerous Goods (General) Regulations, Chapter 295, Laws of Hong Kong before they are put into use in Hong Kong.
- iii. the installation conforming to FSD Circular Letter No. 1/2002 Rules for Fire Detection and Alarm Systems for Buildings; and
- iv. the components used in the installation being compatible.

Yours faithfully,


(YAU Chi-on)
for Director of Fire Services

Ref. : (21) in FP 206/0877 VIII

YCO/aywc