

消防處
牌照及審批總區
香港九龍尖沙咀東部康莊道1號5樓
消防總部大廈



**FIRE SERVICES DEPARTMENT
LICENSING AND CERTIFICATION
COMMAND**

FIRE SERVICES HEADQUARTERS BUILDING,
No. 1 Hong Chong Road, 5/F.,
Tsim Sha Tsui East, Kowloon,
Hong Kong

本處檔號 Our Ref.: (44) in FP 206/0877 VI
來函檔號 Your Ref.:
電訊掛號 Telex: 39607 HKFSD HX
圖文傳真 Fax: (852) 2367 3631
電子郵件 E-mail: lcpolic2@hkfsd.gov.hk
電話 Tel. No.: 2733 7596

3 September, 2002

Fike Protection Systems
Division of Fike Corporation
704 south 10th Street, P.O. Box 610
Blue Springs
Missouri 64013
USA

Dear Sirs,

Application for Approval of Fire Detection/Control Systems

I refer to my interim reply of 19.7.2002 on the captioned subject.

The following fire control unit, which was certified by the Underwriters Laboratories Inc. (UL), has already been accepted by this Department for use in Hong Kong :-


Manufacturer	:	Fike Protection Systems, Div. of Fike Corp.
Type	:	Control Unit with Releasing Device Service
Model	:	SHP
Testing Standard	:	UL 864
Test Report	:	File S2203 Project 95NK26185 issued by Underwriters Laboratories Inc. (UL) on 12.3.1996 and revised on 29.8.1996.

Please note that the acceptance of the above is subject to :-

- i) the installation conforming to FSD Circular Letter No. 1/2002 Rules for Fire Detection and Alarm Systems for Buildings ;

- ii) all conditions as stipulated in the above-mentioned test report being complied with; and
- iii) all components used in the installation being compatible.

Yours faithfully,



(LI Kin-yat)
for Director of Fire Services

LKY/cwy